

ADDENDUM #1

WILDWOOD STORMWATER/UFAS COMPLIANCE 2017- PENINSULA HOUSING AUTHORITY

Date: June 16th, 2017

The following changes/clarifications are hereby incorporated into the Contract Documents for the Wildwood Stormwater/UFAS Compliance 2017 – Peninsula Housing Authority.

- 1) The estimated construction timeframe as shown in the Invitation to Bid is extended to October 27th, 2017. Please note that the time for completion of 90 calendar days in the General Conditions remains unchanged.
- 2) The Contractor shall give a minimum of 48 hours notice to the Owner prior to any planned disruption of utility services.
- 3) Manhole connections for the 42” diameter detention piping may be grouted connections. All other manhole connections must be made using a manhole adapter as noted in the plans and specifications.

There is no change to the bid date for this project.

Acknowledgement:

The undersigned bidder hereby acknowledges receipt of Addendum # 1.

Bidder: _____

By: _____

Date: _____